



74 Kent Street
Brooklyn, New York 11222

Phone (718) 383-5080
Fax (718) 383-7445
E-mail: dllabs@aol.com

Accredited by National Voluntary Laboratory Accreditation Program - Lab Code 100252
ISO/IEC 17025 and relevant requirements of ISO 9002

June 6, 2005

Vexcon Chemicals, Inc.
7240 State Road
Philadelphia, PA 19135

Att: **Mr. Darryl Manuel**

Re: **DL-14525**
Via FAX (215) 332-9997

OBJECTIVE

To evaluate submitted coated concrete panels for scrub resistance.

PRODUCT TESTED

Triplicate 3" X 6" X 1" coated concrete panels were submitted by Vexcon Chemicals. The panels were labeled Certi-Shine Gray Stain Blocks.

TEST PROCEDURE

The Certi-Shine Concrete Gray blocks were tested for wet abrasion following procedures outlined in ASTM D 2486, modified. The blocks were placed on a washability tester and scrubbed using a brush and abrasive scrub medium until we could visually see the coating beginning to be removed.

TEST RESULTS

The panels did not begin to exhibit any removal of the coating until after 5,500 cycles.

DL Labs, Inc.

Thomas J. Sliva
Vice President/
Technical Director

cc: M. Lazaro, Jr.